



Winning Strategies

*Ashbridges Bay Treatment Plant
Wet Weather Flows Management
and
Humber Treatment Plant
Odour Control Strategy*

Ajay Puri and Katrina Blom
City of Toronto



Presentation Outline



Case Study 1

- **ABTP Wet Weather Flows Management**

Case Study 2

- **HTP Odour Control Strategy**
- **Conclusions**

Ashbridges Bay Treatment Plant

**Rated capacity
817 MLD**




ABTP Wet Weather Flows



- **ABTP Rated capacity 817 MLD**
- **High peak wet weather flows ~ 3300 MLD**
- **A shortfall of approx. 800 MLD preliminary/primary capacity**
 - 2,500 MLD firm compared to 3,300 MLD required

Ashbridges Bay Treatment Plant



Wet Weather Flows - The Plan

- Preliminary/Primary Treatment Study
 - Pilot Test Technologies (HRT)
 - Establish a preferred alternative
- The VE Study
- Design and construction




P Building Study – Key Drivers

- **Poor effluent quality during high flows**
- **P Building headworks in poor condition**
- **Clarifiers 1 to 6 at end of life**
- **Odours from P Building preliminary works & primary tanks**



P Building Study – Preferred Alternative

- Headworks
 - capacity 2500 ML/d
 - fine screens & continuous grit removal
- Primary tanks 1 to 6 abandoned & replaced with HRT
- Clarifiers 7 to 9 upgraded with chain & flight & covers
- Biofilter



The VE Team

City of Toronto

- Toronto Water
- Technical Services

VE Consultant – NCE Value Engineers Inc.

Study Consultant – CH2M Hill Canada Ltd.



VE Objective

- Evaluate the preferred alternative
- Evaluate treatment technologies
- Identify and incorporate project-related risks into recommended VE ideas




VE Ideas

- **Generated – 150**
- **Developed – 30**
- **Created an alternative concept to baseline**



VE Alternative Concept


- Split treatment for D Building
- Staged upgrade of P Building and Primary Clarifiers
- Estimated Savings \$99



VE Alternative Concept


The VE Concept:


- Split Treatment for D Building
- P Building headworks upgraded to 1300 ML/d



VE Alternative Concept – Cont'd

- Clarifiers 7 to 9 retained
 - Staged odour control upgrades
 - CEPT pilot testing
 - CEPT implemented if trials successful
- HRT with fine screens
 - Capacity based on CEPT trials & CSO requirements





- **FUTURE Storm Flow Scenario**
- **Unit Process Capacities in ML/day (firm in brackets)**

Risk Assessment

- Risk specialist part of VE team
- Risk assessment objective
 - Support for ideas
 - Identify key areas of improvement based on risk



Risk Assessment

Risk identification

- Entire group

Initial scoring

- Risk Specialist & Selected Experts

First scoring review

- Consultants & City Operators

Second scoring review

- City Team



Risk Assessment Table



Ashbridges Bay Treatment Plant - P Building

Risk Assessment

Low Low likelihood of occurrence
 Medium Moderate likelihood of occurrence
 High High likelihood of occurrence

1 Little negative effect
 2 Moderate negative effect
 3 High negative effect


VE Idea	Risk ID	Potential Risk compared to Alternative E	Construction		Operation		Stakeholders		Combined Rating
			Prob	Cons	Prob	Cons	Prob	Cons	
F	Flooding Potential								
F-08	Raise the channel walls to keep the water in	Structural failure (walls, piles) and release of sewage	1	2	1	2	1	2	4
		Structural failure (walls, piles) and without release of sewage	1	1	1	1	1	0	1
		Raised hydraulic grade line creates community flooding	0	0	0	0	1	3	3
O	Odours								0
O-04	Use HRT for all plant flows and don't do primaries at the D building	Process does not perform as designed	0	0	1	1	1	1	2
		Process fails catastrophically	0	0	1	3	1	3	6
		Sludge backup	0	0	3	2	3	2	12
		HRT does not fit the dry weather hydraulic grade line	0	0	1	2	1	2	4
O-05	Use all HRT at P building	Process does not perform as designed	0	0	1	1	1	1	2
		Process fails catastrophically	0	0	1	3	1	3	6




Thank you!



Humber Treatment Plant



Humber Treatment Plant



Why an Odour Study?

- Odour studies at other Wastewater Treatment Plants in the City
- New Odour Guidelines from Ministry of the Environment
- New condominiums in close proximity to the plant
- Good neighbour initiative
- Odour scrubber near end of design life






The Team

City of Toronto


- Toronto Water
- Technical Services

VE Consultant – NCE Limited/NCE Value Engineers Inc.

Current Worst-Case Odour Impact from Consolidated Data



Contribution to Total Odour by Source





HTP Odour Control – Project Goals

- **Air management strategy optimizing volume of air to be collected, conveyed and treated**
- **Innovative, economical and sustainable odour treatment**
- **Regulatory compliance**



HTP Odour – VE PPlan

- **5-day Value Engineering Workshop**
- **Dispersion Modelling**
- **2-day Risk Management Workshop**



Function Analysis

- **Higher Order Functions**
 - **Maintain C of A**
- **Basic Functions**
 - **Obtain C of A**
 - **Limit Complaints**
 - **Meet Air Quality Standards**



VE Ideas

- **Generated – 155**
- **Developed – 42**
- **Created an alternative concept to baseline**

VE Conceptual Ideas Phase 1 (2008-2011)

Headhouse/North Grit

- Process equipment upgrades
- Isolate inlet sewer
- Screen room air to carbon scrubber
- Process air to aeration or bioscrubber

Primary Tanks/Main Scrubber

- Primary tanks weir covers & biofilters
- Decommission wet chemical scrubber



VE Conceptual Ideas Phase 3 (2013-2016)

North Primary Tank Upgrades

- Prepare tanks for covers
- Refurbish sludge & scum process equipment
- Convert bridges to chain & flight (3B)
- North primary tank covers & biofilters (3B)



VE Conceptual Ideas Phase 4 (2017-2018)

Aeration Tanks

- Biofilter



Preferred Odour Control Technologies

Headhouse/North Grit

- Process air – aeration tanks/bioscrubber
- Bar screen building air – activated carbon

Digesters

- Process biogas – thermal oxidation (via existing co-generation and flares)



Preferred Odour Control Technologies

North and South Primary Tanks

- Process/building air – biofilter

Aeration Tanks/Main Scrubber

- Process air – biofilter


Sludge Thickening Building

- Process air – activated carbon






HTP Odour VE – Concept Strategy






Humber Odour Reduction Program



2017 Odour Impact (2.1 OU)





HTP Odour Control Program Highlights

- Divides implementation into manageable Phases
- Scheduled around retooling needs
- Implements projects with 'greatest odour reduction per dollar first
- Achieves ~70% OU reduction in first four years
- Phase 1 RFP and Phase 2 tender fast-tracked



HTP Odour Control Program Costs

- **Original Odour Study -18 Concept Designs**
- **Implementation costs - \$85 to \$145 million**
- **After Value Engineering - \$75 million**
- **~12% cost savings or value added**



Conclusions


- **Confirmed the benefit of undertaking VE studies early into the project's lifecycle**
- **Identified an excellent path forward for the City in both case studies**
- **Provided a reality check for the baseline scenarios**



Acknowledgements

- **Tim Constantine – CH2M HILL Limited**
- **Denise Costa – CH2M HILL Limited**
- **David Wilson – NCE Value Engineers Inc.**
- **Nancy Bonham, Voitek Kozakiewicz, Colin Marshall, Susan Atlin, George Theodorlis, Emily Zeggars – City of Toronto**

Questions and Answers





Thank you!

